

år 2006	EL	Vand	Varme	Varme korr.	Varme korr.	Areal
Adresse	kWh	m3	m3	m3	Ber.MWh	m2
Odense, WP9	216.570	829	14.389	15.255	710	5.931
Odense, WP15	1.034.428	3.379	40.859	43.319	2.015	7.021
Odense, WP17	299.060	527	12.185	12.919	601	3.482
Odense, WP19	558.510	1.307	7.763	8.230	383	5.263
Odense, WP21	1.409.907	1.763	26.178	27.754	1.291	7.963
Odense, WP23	513.370	571	11.039	11.704	544	3.141
Odense, WP25	894.630	802	15.921	16.880	785	6.583
Odense, WP SUM (SDU+OUH)	4.926.475	9.178	128.334	136.062	6.328	39.384
Odense, WP SUM (SDU-OUH)	2.482.140	4.036	61.297	64.988	3.023	24.400
Odense, Campusvej 55	14.281.400	46.547	248.720	263.698	13.798	150.591
Odense, fradrag svømmehal	-483.200	-15.052	-18.336	-19.440	-1.017	-2.943
Odense, fradrag B1913	-138.117	-909	-3.191	-3.383	-177	-1.827
Odense, fradrag byggepladser						
Odense i alt	16.142.223	34.622	288.490	305.863	15.627	170.221
Esbjerg, Niels Bohrs Vej 9	210.505	775			453	6.040
Esbjerg, Niels Bohrs Vej 10	98.751	574			194	2.085
Esbjerg i alt	309.256	1.349			647	8.125
Kolding, Engstien 1	386.445	2.097			807	10.153
Kerteminde, Hindsholmvej 11	71.637	1.667			31	603
SUM Syddansk Universitet	16.909.561	39.735			17.111	189.102

Graddage 2006	2.740
Graddage normal-år	2.905

Afkøling WP	40
Afkøling Campus	45
Afkøling NBA 1	40

	Ansatte	Studerende	Årsværk
Odense	2.029	12.630	14.659
Kolding	132	2.082	2.214
Esbjerg	100	718	818
Sønderborg	122	1.188	1.310
SUM	2.383	16.618	19.001

SDU totalt 2006

	EL	Vand		Varme korr.
	kWh	m3		Ber.kWh
forbrug / m2	89	0,21		90
forbrug / årsværk	890	2,09		901

SDU Odense 2006

	EL	Vand		Varme korr.
	kWh	m3		Ber.kWh
forbrug / m2	95	0,20		92
forbrug / årsværk	1.101	2,36		1.066

SDU Øvrige 2006

	EL	Vand		Varme korr.
	kWh	m3		Ber.kWh
forbrug / m2	41	0,27		79
forbrug / årsværk	177	1,18		342

år 2009	EL	Vand	Varme	Varme korr.	Varme korr.	Areal
Adresse	kWh	m3	m3	m3	Ber.MWh	m2
Odense, WP9	273.539	973	14.410	14.657	682	5.931
Odense, WP15	848.468	3.347	32.493	33.050	1.537	7.021
Odense, WP17	314.007	572	9.096	9.252	430	3.482
Odense, WP19	622.944	1.303	8.207	8.348	388	5.263
Odense, WP21	1.145.666	1.531	24.393	24.812	1.154	7.963
Odense, WP23	609.713	770	19.602	19.938	927	3.141
Odense, WP25	960.021	926	17.391	17.689	823	6.583
Odense, WP SUM (SDU+OUH)	4.774.358	9.422	125.592	127.747	5.942	39.384
Odense, WP SUM (SDU-OUH)	2.780.224	4.544	68.706	69.885	3.250	24.400
Odense, Campusvej 55	13.131.700	43.169	242.747	246.912	12.920	150.591
Odense, fradrag svømmehal	-430.130	-14.867	-19.242	-19.572	-1.024	-2.943
Odense, fradrag B1913	-143.974	-729	-2.556	-2.600	-136	-1.827
Odense, fradrag byggepladser						
Odense, Niels Bohrs Alle 1	1.115.288	4.920	53.648	54.568	2.538	40.000
Odense i alt	16.453.108	37.037	343.303	349.193	17.548	210.221
Esbjerg, Niels Bohrs Vej 9	217.649	820			434	6.040
Esbjerg, Niels Bohrs Vej 10	83.536	566			181	2.085
Esbjerg i alt	301.185	1.386			615	8.125
Kolding, Engstien 1	373.509	2.012			829	10.153
Slagelse, Willemoesvej 2A	174.401	890			190	3.526
Kerteminde, Hindsholmvej 11	73.893	108			39	603
Alsion 2, Sønderborg	1.122.689	2.551			846	16.987
SUM Syddansk Universitet	18.498.785	43.984			20.068	249.615

Graddage 2009	2.856
Graddage normal-år	2.905

Afkøling WP	40
Afkøling Campus	45
Afkøling NBA 1	40

	Ansatte	Studerende	Årsværk
Odense	2.476	13.653	16.129
Kolding	147	2.189	2.336
Esbjerg	118	833	951
Sønderborg	167	1.430	1.597
Slagelse	78	1.551	1.629
SUM	2.986	19.656	22.642

SDU totalt 2009

	EL	Vand			Varme korr.
	kWh	m3			Ber.kWh
forbrug / m2	74	0,18			80
forbrug / årsværk	817	1,94			886

SDU Odense 2009

	EL	Vand			Varme korr.
	kWh	m3			Ber.kWh
forbrug / m2	78	0,18			83
forbrug / årsværk	1.020	2,30			1.088

SDU Øvrige 2009

	EL	Vand			Varme korr.
	kWh	m3			Ber.kWh
forbrug / m2	52	0,18			64
forbrug / årsværk	314	1,07			387

år 2010	EL	Vand	Varme	Varme korr.	Varme korr.	Areal
Adresse	kWh	m3	m3	m3	Ber.MWh	m2
Odense, WP9	381.861	842	15.016	12.499	581	5.931
Odense, WP15	1.021.099	3.267	33.342	27.753	1.291	7.021
Odense, WP17	309.775	833	15.706	13.073	608	4.320
Odense, WP19	511.787	1.483	9.736	8.104	377	5.263
Odense, WP21	1.132.195	1.470	29.913	24.899	1.158	7.963
Odense, WP23	606.206	729	22.270	18.537	862	3.141
Odense, WP25	934.377	853	18.982	15.800	735	6.583
Odense, WP SUM (SDU+OUH)	4.897.300	9.477	144.965	120.666	5.612	40.222
Odense, WP SUM (SDU-OUH)	2.744.006	4.740	81.710	68.014	3.163	25.238
Odense, Campusvej 55	12.990.814	44.441	264.030	219.773	11.500	150.591
Odense, fradrag svømmehal	-435.283	-14.303	-18.485	-15.387	-805	-2.943
Odense, fradrag B1913	-154.723	-737	-4.338	-3.611	-189	-1.827
Odense, fradrag byggepladser	-84.717	-64				
Odense, Niels Bohrs Alle 1	1.089.681	5.631	75.747	63.050	2.933	40.000
Odense i alt	16.149.778	39.708	398.664	331.839	16.602	211.059
Esbjerg, Niels Bohrs Vej 9	209.054	1.231			567	6.040
Esbjerg, Niels Bohrs Vej 10	78.341	889			224	2.085
Esbjerg i alt	287.395	2.120			790	8.125
Kolding, Engstien 1	341.503	1.365			812	10.153
Slagelse, Willemoesvej 2A	162.119	1.116			364	3.526
Kerteminde, Hindsholmvej 11	74.782	135			44	603
Alsion 2, Sønderborg	1.114.580	3.161			819	16.987
SUM Syddansk Universitet	18.130.157	47.605			19.431	250.453

Graddage 2010	3.490
Graddage normal-år	2.905

Afkøling WP	40
Afkøling Campus	45
Afkøling NBA 1	40

	Ansatte	Studerende	Årsværk
Odense	2.547	14.698	17.245
Kolding	161	2.035	2.196
Esbjerg	128	889	1.017
Sønderborg	167	1.533	1.700
Slagelse	75	1.631	1.706
SUM	3.078	20.786	23.864

SDU totalt 2010

	EL	Vand			Varme korr.
	kWh	m3			Ber.kWh
forbrug / m2	72	0,19			78
forbrug / årsværk	760	1,99			814

SDU Odense 2010

	EL	Vand			Varme korr.
	kWh	m3			Ber.kWh
forbrug / m2	77	0,19			79
forbrug / årsværk	936	2,30			963

SDU Øvrige 2010

	EL	Vand			Varme korr.
	kWh	m3			Ber.kWh
forbrug / m2	50	0,20			72
forbrug / årsværk	299	1,19			427